

SECTION 06 10 00 - CARPENTRY

PART 1 - GENERAL

1.01 DESCRIPTION

- A. The work includes but is not limited to rough carpentry, ~~wood trusses,~~ finish carpentry and casework.

1.02 QUALITY ASSURANCE

~~A. Wood Trusses; Comply with Truss Plate Institute recommendations and publications as applicable.~~

~~B.A.~~ Casework: Comply with Architectural Woodwork Institute "Architectural Woodwork Quality Standards" latest edition, section 400 as applicable, custom grade.

1.03 SUBMITTALS

~~A. Wood trusses; submit shop drawings to architect of record.~~

~~B.A.~~ Casework; submit shop drawings to architect of record.

~~C.B.~~ Fire Retardant Treatment for Wood: Submit to architect of record and Walgreens; manufacturer, name of process and warranty terms.

PART II - PRODUCTS

2.01 LUMBER AND TRUSSES

- A. Comply with PS 20 "American Softwood Lumber Standard".
- B. Factory mark each piece of lumber with grade stamp evidencing compliance with grading rules and moisture content.
- C. Dress lumber; dressed S4S.
- D. Provide lumber with 19% moisture content at time of dressing.
- E. Provide grade and species as required by the architect of record.
- F. Provide treated lumber for exterior framing and as required by local codes.

2.02 SHEATHING & PANELS

~~A. Roof Sheathing: Provide 5/8" minimum thickness plywood, APA rated for exterior use. Oriented Strand Board (OSB) is not acceptable.~~

~~B.A.~~ Wall Sheathing:

- ~~1. Plywood: APA rated for exterior exposure, 5/8" minimum thickness. Oriented Strand Board (OSB) is not acceptable.~~
2. Glass Mat Gypsum Boards: Dens-Glass Gold or Dens-Glass Gold Fireguard, by Georgia-Pacific Corp., or GlasRock™ by BPB America, Inc., 5/8" minimum thickness.

3. Fiberock® Brand Sheathing, 5/8" minimum thickness, by U.S. Gypsum Company.
- C. Plywood backing for telephone/electrical, APA C-D plugged - in with exterior glue 3/4" minimum thickness, install with "C" face exposed.

2.03 WOOD TREATMENT

- A. Preservation Treatment: Comply with applicable standards of AWWA C2 (lumber) and C9 (plywood) and AWPB listed below:
 1. Pressure-treat above ground items with water-borne preservatives complying with AWPB LP-2. After treatment, kiln-dry lumber and plywood to a maximum moisture content, respectively, of 19% and 15%.
 2. Pressure-treat ground or water contacting members complying with AWPB LP-22.
- B. Fire Retardant Treatment: Comply with AWWA C-27 as applicable. Process shall not promote premature degradation of wood products in the conditions in which fire-treated lumber/panels will be installed.
 1. Provide materials with maximum moisture content, after treatment, of 15% or less.
 2. Manufacturer: Interior applications: provide "Dricon FRT" or "Hoover Pyro-Guard" with current warranty.
Exterior applications: provide "Dricon FRX exterior FRT wood or "Hoover Exterior Fire-X".
- C. Fasteners: Provide stainless steel or hot-dipped-galvanized connectors/fasteners. Hot-dipped fasteners/connectors shall be continuous galvanized G185 or G90 HDG per ASTM A-653, batch/post HDG per ASTM A-123 (connectors) ASTM A-153 (fasteners) or mechanical galvanizing per ASTM B-695, class 55 or better.

2.04 PLASTIC LAMINATE FABRICATIONS

- A. All fabrications to be self edged with plastic laminate.
- B. Countertops and sills: Comply with AWI standard 400, custom grade.
- C. Plastic Laminate: nominal 1/16" thick (0.048" +/- 0.005" minimum thickness) materials as follows:
 1. Sill at pharmacy wall & sales area; Wilsonart #1573-60 "Frosty White".
 2. Employee Room countertop with back and side splashes: Pionite #WF131, "Vana", Suede; cabinet: Wilsonart #1573-60 "Frosty White".
 3. Storefront stool: Wilsonart #1573-60 "Frosty White".

~~4. Drive Thru Casework: Laminate panel at drive thru window removable knee wall countertop, side and back panels: Wilsonart #1595-60 "Matte Black".~~

2.05 MISCELLANEOUS

- A. Closet/Storage Shelving: Comply with AWI 600, custom grade, paint finish.
- B. Miscellaneous wood trim; Comply with AWI 300, custom grade, paint finish.

- C. Building Paper: ASTM D 226, Type I, 15 LB, non-perforated asphalt saturated felt.
- D. Hardboard: Opaque, grade II, tempered smooth one side, 1/4" thick.
- E. Cedar Fence: Western Red Cedar or White Cedar with band sawn textured surface.
 - 1. Posts: Galvanized steel posts, concealed on the show side (facing neighbors) by a wood board/picket. Provide ASTM A-90 zinc coating, Type I. Line posts shall be min. 2.375" (nom. o.d.). Corner and terminal posts shall be min. 3.0" (nom. o.d.).
 - 2. Rails: Grade: Standard or Better per NLGA 122b, c, WCLIB 122b, c and WWPA 40.11.
 - 3. Boards: Grade: Custom Knotty per WRCLA.
 - 4. Sealer: Olympic Maximum™ Clear Waterproofing Sealant or Walgreen approved equal.
- F. Employee Room plastic laminate counter and cabinets: Contractor to purchase through Walgreens approved fixture vendor:
 - 1. Contact Creative Cabinets Systems for projects located in the following states: ME, NH,VT, MA, RI, CT, NY, NJ, PA, OH, IN, and MI.

 Creative Cabinets Systems, Inc.
 1 Pop Rite Drive
 Arcanum, OH 45304
 Steve Royer
 937-459-8535
 sroyer@cabsys.com
 - 2. Contact Premier Eurocase for projects in all other states including PR.

 Premier Eurocase
 #8 Forest Hills Drive
 Lincoln, IL 62656
 Dave Faith
 217-553-6626
 dfaith@premiereurocase.com

PART III - EXECUTION

3.01 GENERAL

- A. Securely and properly support and anchor all work to accurate fit, lines, level, and plumb without distortion.
- B. Install fire-retardant treated materials in environments and with proper ventilation to prevent degradation of wood materials.
- C. Metals in contact with pressure treated wood ie; blocking at metal deck, etc., shall be separated by a #15 felt paper.

~~D. Do not cut or alter wood trusses members.~~ |

E.D. Condition woodwork/casework to average prevailing humidity conditions in installation area prior to installing. |

END OF SECTION